CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING No. 7165-0554:149 Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Johnson Controls, Inc. 507 E. Michigan St., Milwaukee, WI 53202-5211

Contact: Jeff Cassidy (414) 524-4358 Fax (414) 524-7055

Jeffrey.L.Cassidy@jci.com

Model IFC-3030, IFC-3030E, IFC2-3030 and IFC2-3030E fire alarm control units. Local, **DESIGN:**

> auxiliary, remote station (PPU), proprietary (PPU), central station (PPU), automatic, manual, releasing service, waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and operational considerations. System components:

ACM-8R/-16AT/-24AT/-32A/-48A **Annunciator Control Modules**

ACPS-2406

Addressable/Charger Power Supply AEM-16AT/-24AT/-32A/-48A **Annunciator Expander Modules** AFM-16A/-16AT/-32A **Annunciator Fixed Modules**

AMPS-24 Addressable Main Power Supply

Auxiliary Power Supply APS-6R Auxiliary Relay Module ARM-4

BB-100/-200 **Battery Box** BMP-1 Blank Module

Smoke Control Enclosures for SCS Modules BGRA-SCS, BGRB-SCS, CEF-SCS, RSA-SCS, RSB-SCS, Smoke Control Enclosures for SCS Modules RSC-SCS, RSD-SCS, RSE-SCS Smoke Control Enclosures for SCS Modules

BP-4 **Battery Panel CAB-4 Series** Enclosure CHG-120 **Battery Charger**

CHS-4L/-4MB/-4N/-6/-M3/-PS/*-BH1 Chassis

Control Relay Expander CRE-4 CRM-4RK Control Relay Module Display Terminal CRT-2 DCM-4RK **Dual Channel Module**

DP-1B Blank Panel

DP-DISP Display Dress Panel DPDW-1B, DPSW-1B, XPDP Dress Panels

Direct Panel Interface **DPI-232** Field Charger/Power Supply FCPS-24 Indicating Control Expander ICE-4 Indicating Circuit Module ICM-4RK IZE-A Initiating Zone Expander IZM-8RK Initiating Zone Module Annunciator Key Switch JAKS-1B Battery Dress Panel JBP2-4

JCI-LBB/-LBBR/-BB-25/-BB-17 **Battery Box** CPU Board JCPU-3030D/JCPU-3030ND JCPU2-3030D/JCPU2-3030ND **CPU Board** JPRN-5/-6 Printer

JNCA-2 Network Control Annunciator LCD-80 Liquid Crystal Display Module

LCM-320/LEM-320 Loop Expander Module

*Corrected 07-10-08 bh

Listing No. 7165-0554:149 Page 2 of 2

LDM-32/-E32/-R32 Lamp Driver Modules
M500XJ Loop Fault Isolator Module

MP-1B Blank Panel

MPS-24B Power Supply Module
NCM-W/-F Network Control Module
N-ELR End of Line Resistors
R-120/-2.2K/-27K/-470/-47K End of Line Resistors
RA-400/-400Z Remote Annunciators

RKS-S Remote Security Keyswitch
RPJ-1 Remote Paging Jack

RPT-W/-F/-485W/-485WF Repeater

RM-1/-1SA Remote Microphone
SCS-8 Smoke Control Station
SCE-8 Smoke Control Expander
STS-1 Security Tamper Switch
TM-4 Transmitter Module

TR-A4/-B4/-C4/-D4
UDACT
UZC-256
VCE-4
VCM-4RK

Trim Ring
Universal DACT
Universal Zone Coder
Voice Control Expander
Voice Control Module

VP-2B Dress Panel

VS4095 Keltron Remote Printer

XP5-C/-M Transponder

XPC-8 Transponder Control Module

XPIQ Transponder Quad Intelligent Audio Module

XPM-8/-8L Transponder Monitor Modules
XPP-1 Transponder Processor
XPR-8 Transponder Relay Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and

indicating devices. Refer to listee's Installation Instructions Manual for details. This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal

(for total evacuation) in accordance with NFPA 72, 2002 Edition.

NOTE: For <u>Fire Alarm Verification Feature</u> (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

XL: 7165-0028:224

*Corrected 07-10-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JULY 22, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division